

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No F 6/DFS/MS/2024/WZ/School/ 1018

Dated: 14/10/2024

FIRE SAFETY CERTIFICATE

Certified that the **D A V Public School** located at **Sector-07, Rohini, Delhi-110085** comprised of **Ground + Three Upper floors** owned/ occupied by **D A V Public School** was issued Fire Safety Certificated vide this office letter no. **F.6/DFS/MS/2021/WZ/School/923 dated 05.11.2021**. The premise was re-inspected by the officer concerned of this department on **06.09.2024** in the presence of **Mr. Chiraj Chugh (Accountant)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from 14/10/2024 for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on 14/10/2024 at New Delhi


(Atul Garg)
DIRECTOR
Ph; 011-23414000
de

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, DAV Public School, Sec-07, Rohini, Delhi-110085.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

INSPECTION REPORT

1. Name & address of the building	D A V Public School, Sec-07, Rohini, Delhi-110085.
2. Type of Occupancy	Educational
3. Type of Case	Renewal (Ground + 03 Upper floor)
4. Details of previous NOC	F.6/DFS/MS/2021/WZ/School/923 dated 05.11.2021
5. Fire Safety directives letter No	NBC Part-04
6. Date of inspection	06.09.2024
7. Name of the Inspecting Officers	A.K.Sharma ADO (Rohini)
8. Name and designation of officers from the building side	Mr. Chiraj Chugh (Accountant)
9. Year of Construction	1994-2006
10. Applicant's letter No.	Online e-mail dated 01.08.2024.

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	5 m	MR
	• Width of internal road	- N/A -	-N/A-	-N/A-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	04	04	MR
	• Basements	-N/A-	-N/A-	-N/A-
	b. Width of staircases			
	• Upper Floors	1.50m	1.75m, 1.36m, 1.41 m, 1.80 m & 1.41- 142m	MR
	• Basements	-N/A-	-N/A-	-N/A-
	c. Protection of exits			
	• Fire check door	-N/A-	-N/A-	-N/A-
	• Pressurization	-N/A-	-N/A-	-N/A-
	d. No. of continuous staircases to terrace	02nos.	Provided	MR
	e. Width of Corridor	-N/A-	-N/A-	-N/A-
f. Door Size	1 m	1 m	MR	
3	Compartmentation.			
	• Fire check door	- N/A -	-N/A-	-N/A-
	• Sealing of electrical shafts	-N/A-	-N/A-	-N/A-
	• Fire Rating of shaft door	-N/A-	-N/A-	-N/A-
	• Water Curtain	-N/A-	-N/A-	-N/A-
	• Fire Dampers	-N/A-	-N/A-	-N/A-
4	Smoke Management System.			
	• Basements	- N/A -	-N/A-	-N/A-
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	30 nos	30 nos	MR
	• Types	ABC/Co2	ABC-26 / Co2- 4	MR
	• ISI marking	ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	03 each floor	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	-N/A-	-N/A-	-N/A-
	• Location of Main Panel	-N/A-	-N/A-	-N/A-

	<ul style="list-style-type: none"> Location of Repeater Panel Alternate source of power Hooters' Location 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
8	MOEFA	Required	Provided	-N/A-MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
11	Internal Hydrants	100mm	Provided	MR
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	03	Provided	MR
		03	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	03	Provided	MR
		03	Provided	MR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power Supply Auto Starting of pump 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		900 lpm	Provided	MR
		36m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		10,000 ltrs	Provided	MR
		Required	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
17	Standby power supply	N/A	125 KVA	MR
18	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-

	• PA System Panel	-N/A-	-N/A-	-N/A-
	• Batter backup	-N/A-	-N/A-	-N/A-
	• Building Floor Plans	-N/A-	-N/A-	-N/A-
20	Special Fire Protection Systems for Protection of special Risks, if any:	-N/A-	-N/A-	-N/A-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F.6/DFS/MS/2021/WZ/School/923 dated 05.11.2021** is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Ajay Kumar Sharma
10/10/24

Signature of the Inspecting Officer
Name **Ajay Kumar Sharma**
Designation **ADO (Rohini)**

DO (NW) - on leave

Depto (W2) - on MR

CFO/ 10/10/2024

Director [Signature]

FT letter is put up for kind perusal and signature please.

Ajay
10/10/24

Director [Signature]