


"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"



**DELHI JAL BOARD ;(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT HAIDERPUR,
DELHI-110085.**



International Year
of Cooperatives
Cooperatives Build a Better World



(ISO Certified 9001:2015)

**THE TEST REPORT IS
FOR THIS PARTICULAR
WATER SAMPLE ONLY**

Water samples collected from S1:- D.J.B Stored, S2:- After RO of DAV Public School, Sector-07, Rohini, Delhi – 110085, vide challan no. 188 dated 09.10.2025.


S. No.	PARAMETERS	UNITS	B.I.S.10500:2012		S1	S2
			Desirable	Permissible		
1.	Date of Collection	--	---	---	30.10.2025	30.10.2025
2.	Date of Analysis	--	---	---	01.11.2025	01.11.2025
3.	Colour	C.U.	5	15	2 C.U.	2 C.U.
4.	Odour	--	Agreeable		Agreeable	Agreeable
5.	Turbidity	N.T.U.	1.0	5.0	2.56	1.35
6.	pH value	--	6.5 to 8.5	N.R.	7.6	6.9
7.	Electrical Conductivity	µs/cm	----	-----	312.0	125.0
8.	Total Dissolved Solid	(mg/l)	500	2000	202.8	81.25
CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	(mg/l)	----	----	Nil	Nil
10.	Total Alkalinity	(mg/l)	200	600	80.0	29.0
11.	Total Hardness	(mg/l)	200	600	148.0	27.0
12.	Calcium Hardness	(mg/l)	----	----	93.0	9.0
13.	Magnesium Hardness	(mg/l)	---	----	55.0	18.0
14.	Calcium as Ca	(mg/l)	75	200	37.2	3.6
15.	Magnesium as Mg	(mg/l)	30	100	13.2	4.32
16.	Ammonia (as NH ₃ -N)	(mg/l)	0.5	N.R.	ND	ND
17.	Nitrite –Nitrogen (N)	(mg/l)	---	---	ND	ND
18.	Nitrate NO ₃	(mg/l)	45	N.R.	2.72	4.69
19.	Sulphate (SO ₄)	(mg/l)	200	400	46.20	8.38
20.	Chloride (Cl)	(mg/l)	250	1000	14.0	18.0
21.	Iron (Fe)	(mg/l)	1.0	N.R.	0.02	ND
22.	Fluorides (F)	(mg/l)	1.0	1.5	0.38	0.18
23.	Cyanides (CN)	(mg/l)	0.05	N.R.	ND	ND
24.	Residual Chlorine	(mg/l)	0.2	1.0	0.35	Nil
BACTERIOLOGICAL EXAMINATION						
25.	Coli form per 100 ml at 37 ⁰ c	MPN/100 mL	0	0	0	0

Remarks: On the basis of tested parameters, water sample 'S1' & 'S2' confirms to drinking water specification IS.10500:2012 & may be used for drinking purpose.

Neeta
31/11/25
Asstt. Chemist

19
31/11/25
Chemist/Bacteriologist

Amey
06/11/25
A.C.W.A.



MUNICIPAL CORPORATION OF DELHI
(Office of Dy. Health Officer: Rohini Zone)

Public Health Department

Sector 5 Rohini Delhi -110085

Email: dhorohinizone15@gmail.com Tel: 011-27052106

No.-DHO/RZ/2025/859

Date : 05/03/2025

SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed Asst. Public health Inspector from Public Health department Rohini Zone inspected the the **DAV Public School** at **Sec-7, Rohini Delhi-85** and found that the **DAV Public School** at **Sec-7, Rohini Delhi-85** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus.

The above certificate is valid for the period of one year from date of issue.


Dy. Health Officer

Rohini Zone

Deputy Health Officer
Municipal Corporation of Delhi
Rohini Zone

Principal

DAV Public School

Sector-7, Rohini

Delhi-110085.